

CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-R19339
Report Reference R19339-20000328
Issue Date 2019-NOVEMBER-07

Issued to: NATIONAL GUARD PRODUCTS INC
4985 E RAINES RD
MEMPHIS TN 38118-7024

This certificate confirms that representative samples of FIRE DOOR GLASS LIGHT FRAMES
Refer Addendum page for Models/Product

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B - Standard for Fire Tests of Door Assemblies
ANSI/UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies
CAN/ULC S104-10 Fire Test of Door Assemblies

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-R19339
Report Reference R19339-20000328
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

Fire door glass light frame, Models, L-CVFM-SS, L-CVFM-SS-SP, L-GLF100-SP-TB, L-GLF100-TB, L-GLF100-SP, L-GLF100, L-FRA100, L-FRA100-SP, L-SG100 and L-SG100-TB. The Light kits may be provided with mullions as described under "CONSTRUCTION SPECIFICATIONS". When provided the above model numbers will be suffixed with one of the following as appropriate: G2-G4, G6, G8-G10, G12, G15, G18, G21, G24, G-SP or STC. The "STC" option includes 2525 Silicone Bulb Seal around both pieces of the frame to reduce sound transmission.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



Certificate of Compliance

Certificate Number:

R19339

Report Reference:

R19339-19830822

Issue Date:

2024-03-27

Issued to:

**National Guard Products, Inc.
4985 E RAINES RD
MEMPHIS TN, 38118-7024 United States**

This certificate confirms that representative samples of:

FIRE DOOR GLASS LIGHT FRAMES

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**ANSI/UL 10B, “Fire Tests of Door Assemblies”
ANSI/UL 10C “Positive Pressure Fire Tests of Door Assemblies”**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL’s Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number R19339
Report reference R19339-19830822
Date 2024-03-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Fire door glass light frame, Models LoPro, LoPro-IS.



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

