




INSTALLATION INSTRUCTIONS

140S

Astragal Seal



BHMA
CERTIFIED

See ngp.com for
All Applicable
Certifications for
this Product.



POSITIVE PRESSURE
TESTED GASKETING
MATERIALS FOR
FIRE DOORS FOR
APPLICATION TO
HOLLOW-METAL-
TYPE FIRE DOORS
RATED UP TO 3
HOURS AND WOOD-
TYPE FIRE DOORS
RATED UP TO
1½ HOURS.
CATEGORY J

Install only
on outside of
outswinging
door or inside of
inswinging door.

1. Cut astragal to length. Cut from one end, not closer than 1" to the adjusting screw. If necessary to shorten more, cut other end.
2. Position seal on door as shown above.
3. Loosely secure the top screws, bottom screws, and center screws.
4. Once properly aligned, tighten these screws, and install remaining screws.
5. Adjust astragal so it does not impede proper closing and latching of the doors.

ngp.com

1-800-NGP-RUSH

FAX: (800) 255-7874

QUOTES: quotes@ngp.com

ORDERS: orders@ngp.com

NGP MEMPHIS

4985 East Raines Road

Memphis, TN 38118

CARSON CITY

3689 Arrowhead Drive

Carson City, NV 89706