

HP90-FB

FLUSH BOLT HARDWARE PREP FILLER



UL Certified Solution for Fire Doors When Either Removing Existing Hardware and/or Using a New Hardware Type Over Existing Hardware Prep's.

PRODUCT INFORMATION

- ▶ Application Certified On Both Hollow Metal And Wood Fire Rated Doors Up To 90-Minutes
- ▶ Patent Pending
- ▶ Certified for Filling Manual or Automatic Flush Bolt Cavities

PRODUCT CONSISTS OF:

- + HP90 – 2" x 6" Rectangular Fire-Rated Panel
- + HP90 – 0.5 Cylindrical Fire-Rated Panel
- + Steel Filler Plates: (*Powder Coated Primer Gray, Embossed With UL Mark*)
 - HP90-FBE6750, Edge Filler Plate
 - HP90-FBE8500, Edge Filler Plate
 - HP90-FBL2000, Latch Bolt Filler Plate
 - HP90-FBL2500, Latch Bolt Filler Plate
 - HP90-FBL3875, Latch Bolt Filler Plate
 - HP90-SF2250, Strike Filler Plate
- + Hardware Pack
 - #10-32 x 1-3/4" FHPH SS machine screw
 - #8 x 3/4" FHPH SS combo screw
 - #12 x 1" FHPH SS combo screw
 - #8 x 3/4" FHPH SS SMS
 - #12 x 1" FHPH SS SMS
- + GapGuard™ Fire Caulk (*see Installation Instructions*)



SPECIAL NOTES:

- 90-minute rated UL Certified Miscellaneous Fire Door Accessory on UL10B and UL10C wood or hollow metal fire doors
- To retain UL Certification, the HP90-MORT must be installed using GapGuard™ Fire Caulk